



P.O. Box 152837
Dallas, TX 75315

A-L-I SEALED INSULATING GLASS CERTIFICATION PROGRAM

Thermal Windows & Doors, LLC
3700 Haney Ct.
Murrysville, PA 15668

Plant Code: TI-1

NOTICE OF CERTIFICATION AUTHORIZATION

Test Method: ASTM E 2188-10
Specification: ASTM E 2190-10

The sealed insulating glass described below is hereby approved for listing in the current A-L-I Certified Products Directory.

| Sealant | Desiccant | Spacers (2)* | Corners | Low-E | Gas Fill | Muntins |
|----------------|------------------|-----------------|---------|-----------|----------|---------|
| Hot Melt Butyl | Desiccant Matrix | Stainless Steel | Bent** | Yes (E/D) | Argon | Yes |

*Triple glazed. **Final corner joined using a screw.